

**The CJ/T 188-2004 plugin
PRINTED MANUAL**

CJ/T 188-2004 plugin

© 1999-2024 AGG Software

All rights reserved. No parts of this work may be reproduced in any form or by any means - graphic, electronic, or mechanical, including photocopying, recording, taping, or information storage and retrieval systems - without the written permission of the publisher.

Products that are referred to in this document may be either trademarks and/or registered trademarks of the respective owners. The publisher and the author make no claim to these trademarks.

While every precaution has been taken in the preparation of this document, the publisher and the author assume no responsibility for errors or omissions, or for damages resulting from the use of information contained in this document or from the use of programs and source code that may accompany it. In no event shall the publisher and the author be liable for any loss of profit or any other commercial damage caused or alleged to have been caused directly or indirectly by this document.

Printed: 10/24/2024

Publisher

AGG Software

Production

© 1999-2024 AGG Software

<http://www.aggsoft.com>

Table of Contents

Part 1 Introduction	1
Part 2 System requirements	1
Part 3 Installing CJ/T 188-2004	1
Part 4 Glossary	2
Part 5 Requests queue	3
Part 6 Request method	5
Part 7 Cron time format	6

1 Introduction

The plugin implements reading data from heat and energy meters supporting the communication protocol defined in the Chinese "CJ/T 188-2004" standard. Centralized meter reading system is a system in which the master station can read data of multiple household meters through RS-485, COM ports or Ethernet. This protocol is similar to M-Bus, but adds some unique features.

This protocol adopts a half-duplex communication mode with a master-slave structure. A computer or server acts as the master station that polls multiple meters, which function as slave stations.

This module has the following features:

- The software is capable of extracting real-time data from compatible devices in a user-friendly format.
- This plugin is compatible with both serial and network interfaces, allowing for seamless integration.
- Users can customize the interval at which meter data is retrieved.
- Simultaneous polling of data from multiple devices is supported by this plugin.
- Measurement units and precision are automatically detected by the plugin, eliminating the need for manual configuration.

2 System requirements

The following requirements must be met for "CJ/T 188-2004" to be installed:

Operating system: Windows 2000 SP4 and above, including both x86 and x64 workstations and servers. The latest service pack for the corresponding OS is required.

Free disk space: Not less than 5 MB of free disk space is recommended.

Special access requirements: You should log on as a user with Administrator rights in order to install this module.

The main application (core) must be installed, for example, Advanced Serial Data Logger.

3 Installing CJ/T 188-2004

1. Close the main application (for example, Advanced Serial Data Logger) if it is running;
2. Copy the program to your hard drive;
3. Run the module installation file with a double click on the file name in Windows Explorer;
4. Follow the instructions of the installation software. Usually, it is enough just to click the "Next" button several times;
5. Start the main application. The name of the module will appear on the "Modules" tab of the "Settings" window if it is successfully installed.

If the module is compatible with the program, its name and version will be displayed in the module list. You can see examples of installed modules on fig.1-2. Some types of modules require additional configuration. To do it, just select a module from the list and click the "Setup" button next to the list. The configuration of the module is described below.

You can see some types of modules on the "Log file" tab. To configure such a module, you should select it from the "File type" list and click the "Advanced" button.




Fig. 1. Example of installed module

4 Glossary

Main program - it is the main executable of the application, for example, Advanced Serial Data Logger and asdlog.exe. It allows you to create several configurations with different settings and use different plugins.

Plugin - it is the additional plugin module for the main program. The plugin module extends the functionality of the main program.

Parser - it is the plugin module that processes the data flow, singling out data packets from it, and then variables from data packets. These variables are used in data export modules after that.

Core - see "Main program."

5 Requests queue

To add a new item, click "Actions - Add new request." The dialog window will be shown (fig.1). Enter a request description that can contain any characters and click the "OK" button.




Fig.1. Name dialog

The new data request will appear in the requests tree (fig.2). Each request has a few important options:

Device address - the device address refers to the communication address assigned to a CJ/T meter for point-to-point communications. You should program the unique device address in the meter. The address may contain up to 14 digits. The plugin automatically appends leading zeros to addresses shorter than 14 digits. If there are multiple similar meters on one bus, you can enter several device addresses separated by a semicolon. The plugin will then poll them sequentially.

Device type - refers to the specific type of connected meter or instrument. Each meter type is associated with unique data values that are returned when a request is made. It is important to note that if the device type option does not align with the meter type, the device will not respond.

Request timeout - A request timeout refers to the maximum amount of time a program will wait for a response before canceling the current request. When the timeout limit is reached, the program automatically moves on to the next request in the queue. This ensures that the program doesn't get stuck waiting indefinitely for a response. The timeout value is influenced by two main factors: media speed and device performance. If the data transfer rate over the media is slow, it is advisable to set a larger timeout value. This allows sufficient time for the response to be received, preventing premature cancellation of requests.

Export status of failed requests - when this option is activated, the plugin will export an empty data set accompanied by an error status indicator after encountering 3 consecutive unsuccessful attempts to retrieve data. This functionality can be valuable in identifying and troubleshooting potential communication issues.

Response items - this section may contain only one item.

Function - you can choose between reading the basic or extended data sets from a meter. It is important to note that simpler meters may only include the basic data set.

Requests queue

Property	Value
Request	
<input checked="" type="checkbox"/> Send requests, otherwise parse response only	
Device address	1234567
Device type	Heat meter (0x20)
Request timeout (ms)	2000
<input type="checkbox"/> Export status of failed requests	
Request method	
<input type="radio"/> Once, on the program startup	
<input checked="" type="radio"/> Polling	
Interval	5
Interval units	Second
<input type="radio"/> At specified time	
<input type="radio"/> Time using Unix Cron schedule	
Response items	
Item #1	
Function	Meter data 1

Action ▼

Minimal interval between data packets (ms)

OK Cancel

Fig.2. CJ/T 188-2004 request

Basic data sets

Device type code: 0x10-0x19, 0x30-0x49

Data identification, serial number, current cumulative flow, settlement daily cumulative flow, current meter clock time, meter status 1, meter status 2.

Device type code: 0x20-0x29

Data identification, serial number, settlement day heat/cool energy, current heat energy, current heat power, instantaneous flow, cumulative flow, water inlet temperature, water outlet (return) temperature, cumulative meter operation time, current meter clock time, status 1, status 2.

Extended data sets

Device type code: 0x10-0x19, 0x30-0x49

Data identification, serial number, current cumulative flow, settlement day cumulative flow, Instantaneous flow, temperature, pressure, cumulative meter operation time, current meter clock time, status 1, status 2.

Device type code: 0x20-0x29

Data identification, serial number, settlement day heat energy, settlement day cool energy, current heat power, current cool power, thermal power, instantaneous flow, cumulative total flow, water inlet temperature, water outlet temperature, water inlet pressure, water outlet pressure, cumulative meter operation time, current meter clock time, status 1, status 2.

Data values

The device sends all values with the device-specific precision and units in every data packet. The plugin automatically decodes this information and adds the unit information for all decoded values (if any).

Data identification - it is the data set type number. The basic data set identifier is 0x901F. The extended data set identifier is 0x911F.

Serial number - the device serial number. It may be different with the device address.

Device status

Meter status 1 - the standard-defined bit mask of the meter status. This value is equal 128 (bit 8 is set) when the plugin exports an empty data set for unresponsive devices.

Bit 0 - Valve switch (1 - On, 0 - Off).

Bit 1 - Valve status (1 - Abnormal, 0 - Normal).

Bit 2 - Battery status (1 - Abnormal, 0 - Normal).

Bit 3-7 - Manufacturer-specific status bits.

Meter status 2 - manufacturer-specific status exported as a decimal number.

6 Request method

The plugin can send requests in the following mode:

Once, on program startup - the program will send a request once when the program starts.

Polling - the program will send a request periodically based on an interval specified. The interval between requests depends on the network on which master (program) and slave (device) is running. If the network is slow, then the time for each request will be larger and vice versa. Because the program executes all requests in the queue one by one, the time between requests depends on the number of requests in the queue.

At the specified time - the time of the day using the 24hr format (e.g., 18:00:00). You may specify several time points separated by a semicolon (e.g. 11:00:00;11:20:00;11:40:00).

Time, using Unix Cron schedule - a flexible schedule format that allows sending requests periodically or at the specified time. You can find detailed information about this format and see examples in the "Cron time format" section. The default is 0 0 12 * * *, which means "every week, every day at 12:00:00".

Event - the program executes the corresponding request when the plugin receives an external event. These events can be generated by our other plugins, like "Event generator," "Script execute," "Expressions,"

Request method

Once, on the program startup

Polling

Interval (ms)	10000
Interval units	Millisecond

At specified time

Time using Unix Cron schedule

Event

Fig. 2. Request methods

If you have added several requests to the queue, you can move them up or down. To do it, select a request, click the "Action" button, and select an action ("Move up" or "Move down").

You can also click this button to change a request's description or remove a request from the queue.

You can also perform the same actions by using the context menu that pops up when you right-click items in the request tree.

7 Cron time format

The CRON format is a simple yet powerful way to describe time and operation periodicity. The traditional (inherited from the Unix world) CRON format consists of five fields separated with spaces:

<Second> <Minutes> <Hours> <Month days> <Months> <Weekdays>

Any of the five fields can contain the * (asterisk) character as its value. It stands for the entire range of possible values. For example, every minute, every hour and so on. In the first four fields, you can also use the proprietary "?" (w/o quotes) character. See its description below.

Any field can contain a list of comma-separated values (for example, 1,3,7) or an interval (subrange) of values defined by a hyphen (for example, 1-5).

You can use the / character after the asterisk (*) or after an interval to specify the value increment. For example, you can use 0-23/2 in the "Hours" field to specify that the operation should be carried out every two hours (old version analog: 0,2,4,6,8,10,12,14,16,18,20,22). The value */4 in the "Minutes" field means that the operations must be carried out every four minutes. 1-30/3 is the same as 1,4,7,10,13,16,19,22,25,28.

You can use three-word abbreviations in the "Months" (Jan, Feb, ..., Dec) and "Weekdays" (Mon, Tue, ..., Sun) fields instead of numbers.

Examples

Note: the <Second> field equal 0 in all examples

Format	Description
* * * * *	every minute
59 23 31 12 5	one minute before the end of the year if the last day in the year is Friday
59 23 31 Dec Fri	one minute before the end of the year if the last day in the year is Friday (one more variant)
45 17 7 6 *	every year on the 7th of June at 17:45
0,15,30,45 0,6,12,18 1,15,31 * 1-5 *	00:00, 00:15, 00:30, 00:45, 06:00, 06:15, 06:30, 06:45, 12:00, 12:15, 12:30, 12:45, 18:00, 18:15, 18:30, 18:45, if it is the 1st, 15th or 31st of any month and only on workdays
*/15 */6 1,15,31 * 1-5	00:00, 00:15, 00:30, 00:45, 06:00, 06:15, 06:30, 06:45, 12:00, 12:15, 12:30, 12:45, 18:00, 18:15, 18:30, 18:45, if it is the 1st, 15th or 31st of any month and only on workdays (one more variant)
0 12 * * 1-5 (0 12 * * Mon-Fri)	at noon on workdays
* * * 1,3,5,7,9,11 *	every minute in January, March, May, July, September, and November
1,2,3,5,20-25,30-35,59 23 31 12 *	on the last day of the year at 23:01, 23:02, 23:03, 23:05, 23:20, 23:21, 23:22, 23:23, 23:24, 23:25, 23:30, 23:31, 23:32, 23:33, 23:34, 23:35, 23:59
0 9 1-7 * 1	on the first Monday of every month at 9 in the morning
0 0 1 * *	at midnight on the 1st of every month
* 0-11 * *	every minute till noon
* * * 1,2,3 *	every minute in January, February, and March
* * * Jan, Feb, Mar *	every minute in January, February, and March
0 0 * * *	every day at midnight
0 0 * * 3	every Wednesday at midnight

You can use the proprietary "?" character in the first four fields of the CRON format. It stands for the start time, i.e., the question mark will be replaced with the start time during the field processing: minute for the minute field, hour for the "Hours" field, month day for the month day field, and month for the month field.

For example, if you specify:

? ? * * *

The task will be run at the moment of startup and will continue being run simultaneously (if the user does not restart the program again, of course) – the question marks are replaced with the time the program was started at. For example, if you start the program at 8:25, the questions marks will be replaced like this:

25 8 * * * *

Here are some more examples:

- ? ? ? ? * - run only at startup;
- ? * * * * - run at startup (for example, at 10:15) and continue being run in exactly one hour: at 11:15, 12:15, 13:15 and so on;
- * ? * * * - run every minute during the startup hour;
- */5 ? * * * - run on the next day (if CRON is not restarted) at the same hour every minute and so on every day, once in five minutes, during the startup hour.